

Hardline Laboratory

Report No. : HQ40020/2021

Page : 1 of 4

Date : MAY 03, 2021

ACEGREEN ECO-MATERIAL TECHNOLOGY CO., LTD.

NO. 50, LANE 20, SECTION 1, NANTONG RD., ERSHUI TOWNSHIP, CHANGHUA COUNTY 530, TAIWAN

The following merchandise was submitted and identified by the applicant as:

Product Description: High-efficiency hydro triboelectrification(Polypropylene)
Style/Item No.: ACE-MW-001
Manufacturer/Vendor: ACEGREEN ECO-MATERIAL TECHNOLOGY CO., LTD.
Country of Origin: TAIWAN
Additional Information: Brand: ACEGREEN

We have tested the submitted sample(s) as requested and the following results were obtained:

Test Requested:

1. ASTM F2101:2019
2. EN 14683:2019 Annex C
3. ASTM F2299/F2299M-03 (Reapproved 2017)

Test Method & Result: ---See following sheet(s)---


Date of Receipt: APR. 08, 2021

Testing Period: APR. 08, 2021 ~ MAY 03, 2021

Note:

1. The ASTM F2101:2019 and EN 14683:2019 Annex C tests were performed by O.S.H. CO., LTD. Respirator Test Center.
2. The ASTM F2299/F2299M-03 (Reapproved 2017) testing was performed by SGS Hong Kong Ltd.

Signed for and on behalf of
SGS Taiwan Ltd.


Sturm Su
Asst. Manager



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of client's instruction, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced, except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested

Test Method & Result:

1. ASTM F2101:2019:

Test Methods	Test Item	Test Results
1. Testing Sample Number: 5 2. Test surface : Either 3. Test Area: 49 cm ² 4. Flow rate during testing: 28.3 Liter/min 5. Counts of positive control: 2160 CFU 6. Counts of negative control: 0 CFU 7. Average size: 2.9 μm 8. Sample Model: BFE-1100409001	Bacterial filtration efficiency (BFE) (%)	01 >99.9
		02 >99.9
		03 >99.9
		04 >99.9
		05 >99.9

6 Stage Sample No.	Colonies count of each stage						Total colony count (CFU)
	Stage 1 (7 μm)	Stage 2 (4.7 μm)	Stage 3 (3.3 μm)	Stage 4 (2.1 μm)	Stage 5 (1.1 μm)	Stage 6 (0.65 μm)	
01	0	0	0	0	0	0	0
02	0	0	0	0	0	0	0
03	0	0	0	0	0	0	0
04	0	0	0	0	0	0	0
05	0	0	0	0	0	0	0

2. EN 14683:2019 Annex C:

Test Methods	Test Item	Test Results (mm H ₂ O/cm ²)	Test Results (Pa/cm ²)
1. Testing Sample Number: 5 2. Test Flow Rate : 8.03 Liter/min 3. Pre-Conditioning: Minimum of 4 hours at (21±5) °C and (85±5) % relative humidity. 4. Sample Model: AEP-1100409001	Differential pressure	01 2.78	27.24
		02 2.60	25.48
		03 2.95	28.91
		04 2.56	25.09
		05 3.02	29.60
		Avg. 2.78	27.26

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of client's instruction, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced, except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested

3. ASTM F2299/F2299M-03 (Reapproved 2017)

Test Results: Determining the Initial Efficiency of Materials Used in Medical Face Masks to Penetration by Particulates Using Latex Spheres

Test Side : Either side
 Pre-Conditioning : Minimum of 4 hours at 21±3°C and 30-50±5% R.H.
 Test Condition : 21±3°C and 50±5% R.H.
 Test Area : 41.61 cm²
 Face Velocity : 9.75 cm/s
 Particle Size : 0.1 µm (+/-15% CV) Latex Microspheres
 Average Filtration Efficiency : 99.89%
 Standard Deviation : 0.02
 Sample Model : T32120250219SN




Test Specimen	Pressure Drop (inH ₂ O)	Test Article Counts	Average Control Counts	Filtration Efficiency (%)
1	0.204	412	295062	99.86
2	0.233	363	286445	99.87
3	0.226	301	321636	99.91
4	0.249	245	263692	99.91
5	0.223	278	291888	99.90

Note: The procedure incorporated a non-neutralized challenge. The non-neutralized aerosol is also specified in the FDA guidance document on surgical face masks.

Note :

1. The test report merely reflects the test results of the consigned matters of the client and is not a certification.
2. The content of this report is invalid if it is not presented as the entire report.

– Picture(s) –

	
<p>Photo A: Appearance of the sample - BFE-1100409001</p>	<p>Photo B: Appearance of the sample - AEP-1100409001</p>
	<p>---</p>
<p>Photo C: Appearance of the sample - T32120250219SN</p>	<p>---</p>

---End of Report---

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of client's instruction, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced, except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested